



NOTE:

1. AIR RELIEF VALVE SHALL BE INSTALLED AT THE HIGHEST POINT OF THE SYSTEM ABOVE ALL DRIPLINE LATERALS.
2. ALL VALVE BOXES AND LIDS WITHIN THE SIDEWALK SHALL BE OF TRAFFIC RATED QUALITY.

DATE: 09/22/2007		NOT TO SCALE		CITY OF ELK GROVE - PUBLIC WORKS		APPROVED BY: <i>Paul Muddoch</i>	
REVISION	BY	APPROVED	DATE			CITY ENGINEER	DATE
				<b>AIR RELIEF VALVE</b>		DRAWING NUMBER	
						<b>L - 8</b>	
							