



- NOTE:
1. AIR RELIEF VALVE SHALL BE INSTALLED AT THE HIGHEST POINT OF THE SYSTEM ABOVE ALL DRIPLINE LATERALS.
 2. ALL VALVE BOXES AND LIDS WITHIN THE SIDEWALK SHALL BE OF TRAFFIC RATED QUALITY.

DATE:	NOT TO SCALE
01/18/2007	
REVISION	APPROVED
BY	DATE

CITY OF ELK GROVE - PUBLIC WORKS

AIR RELIEF VALVE

APPROVED BY:

CITY ENGINEER

DRAWING NUMBER

L-8

