



SLOPE OF GUTTER	"A" (APPROX. LENGTH)
0.25% TO 0.65%	6'-0"
> 0.65% TO 1.75%	7'-0"
> 1.75% TO 2.55%	8'-0"
> 2.55% TO 3.20%	9'-0"
> 3.20% TO 3.70%	10'-0"
> 3.70%	SEE NOTE 2

**NOTES:**

1. TYPE 3 CURBING ON SITE SHALL EXTEND TO WHERE THE DRIVEWAY APPROACH IS A MINIMUM OF FOUR INCHES ABOVE THE BACK OF SIDEWALK ELEVATION AT THE DRIVEWAY.
2. LENGTH OF DRIVEWAY FLAIR ON STREETS STEEPER THAN 3.70% SHALL REQUIRE SPECIAL APPROVAL BY DESIGN CHIEF OF THE DEPARTMENT OF TRANSPORTATION.
3. A 1-INCH CONCRETE BATTER SHALL BE PLACED ON ALL CURB LIPS.

DATE: 02/22/2007		NOT TO SCALE		CITY OF ELK GROVE - PUBLIC WORKS		APPROVED BY:  _____	
REVISION		BY		APPROVED		DATE	
<b>COMMERCIAL DRIVEWAYS TYPE A-6</b>						CITY ENGINEER	
<b>COMMERCIAL DRIVEWAYS TYPE A-6</b>						DRAWING NUMBER	
						<b>ST - 20</b>	

