

Address of Project _____ Application # _____

Applicant's Name(printed) _____ Signature _____
(see note below)

RESIDENTIAL BASEMENT FINISH GENERAL NOTES

Supplemental construction notes provided by Hamilton County based on the minimum requirements of the 2013 Residential Code of Ohio and the Hamilton County Building Code

This document, when signed and initialed will become part of the application for permit. The requirements on this document will take precedence over any discrepancies within documents.

The signature of the Applicant above indicates agreement with all of the stated requirements.

- Finished portions of the basement that are not specifically designated as a "bedroom" shall not be used for sleeping purposes. Sleeping shall not occur in other finished basement spaces at any time.
- Smoke detectors shall be provided in each bedroom, outside each sleeping area, and on each level of the existing residence, including the basement. These smoke detectors are permitted to be battery-operated unless located in areas of construction. Smoke detectors located in areas changed by this permit shall be hard-wired with battery back-up, interconnected to each other. Carbon monoxide detector is required if there is an attached garage or gas-fueled appliances in the house.
- All bathrooms without an operable window shall be provided with a minimum 50 cfm exhaust fan vented directly to the exterior of the residence.
- All habitable rooms in the finished portion of the basement shall be provided with natural ventilation or mechanical ventilation. Natural ventilation to be through openable windows/doors equal to 4% of the room floor area. Mechanical ventilation to be minimum .35 air changes per hour.
- All habitable rooms in the finished portion of the basement shall be provided natural light or artificial light. Natural light shall be through exterior glazed areas (windows/doors) equal to 8% of the room floor area.
- Artificial light shall be capable of producing an average illumination of 6 footcandles over the area of the room at a height of 30" above finished floor.
- The ceiling height in the finished habitable portions of the basement shall be min. 6'-8" with not less than 6'-4" below any ceiling projections.
- Lumber in direct contact with concrete or masonry to be pressure-treated for exterior use.
- All structural bolts shall be minimum ½" diameter, corrosion-resistant, and be compatible with the specific type of pressure-treated lumber being used.

Guardrails, Handrails, and Stairs

- Guardrails are required for all open stairs with a total rise 30" or greater above the adjacent basement floor. Existing guardrails & handrails shall be altered to comply with the current residential building code requirements (see below).
- Guardrails & handrails at the open sides of stairs shall have a height between 34"-38" and its balusters shall be installed in a manner that does not allow the passage of a 4⅝" dia. sphere.
- Handrails shall be continuous and, at the top & bottom of the stair, terminate into a post (or return to a wall). Handrails shall be graspable or a finger recess area will be provided.
- The bottom of the basement stair shall have a landing at least 3'-0" deep by the width of the stair landing.
- Illumination shall be provided for the full length stair & its associated landings.

Finishes

- All enclosed, accessible spaces below the basement stair shall have its walls & ceiling finished with minimum ½" gypsum board (drywall).
 - Walls adjacent to the concrete foundation wall shall be provided with minimum R-13 insulation.
 - Moisture-resistant gypsum board (green-board) or approved equivalent (such as cement board) shall be installed adjacent to tubs, whirlpools, & showers.
- All interior (non-bearing) wall studs shall be framed with a minimum 2 X 4 stud grade Spruce-Pine-Fir at a maximum 24" on center with a top and bottom plate.
 - Firestops shall be provided in the air space between the new interior stud wall and the existing cmu (concrete masonry unit) or concrete foundation wall at a maximum of 10 ft. horizontally and at the top of the stud wall.