



NOTES:

1. VILLAGE OF PLEASANT PRAIRIE PUBLIC WATER MAINS - ALL JOINTS SHALL BE RESTRAINED WITH MEGALUGS OR STAINLESS STEEL RODDING IN CONFORMANCE WITH FILE NO. 47 OF THE "STANDARD SPECIFICATIONS."
2. PRIVATE FIRE MAINS AND COMBINATION FIRE/WATER MAINS - ALL JOINTS SHALL BE RESTRAINED WITH MEGALUGS AND STAINLESS STEEL RODDING IN CONFORMANCE WITH SUBSECTION 10.6.2.1.2 OF THE NFPA 24 STANDARD FOR THE INSTALLATION OF PRIVATE SERVICE MAINS AND THEIR APPURTENANCES.
3. ALL FASTENERS SHALL BE STAINLESS STEEL .
4. WHEN NOTED ON THE PLANS OR DIRECTED BY THE VILLAGE, INSULATION SHALL BE INSTALLED BETWEEN THE WATER MAIN AND CONFLICT.
5. REFER TO VILLAGE STANDARD SPECIFICATIONS FOR WATER MAIN CONSTRUCTION

SCALE: NTS

WATER MAIN VERTICAL OFFSET

DETAIL: W - 9

DATE: 5-24-21

APPROVED BY: MATT FINEOUR

VILLAGE OF PLEASANT PRAIRIE
KENOSHA COUNTY, WISCONSIN